



NOTES:

1. ALL FITTINGS TO BE COPPER OR RED BRASS.
2. AUTOMATIC BLOW-OFF ASSEMBLIES ARE TO BE PLACED AT ALL WATER MAIN DEAD ENDS OR WHERE CIRCULATION IS LIMITED. IF DEEMED NECESSARY BY THE ENGINEER OR WATER DEPARTMENT, A WATER SAMPLE STATION MAY BE REQUIRED, SEE DETAIL W-12.



City of San Bruno
Standard Detail

2" AUTOMATIC BLOW-OFF ASSEMBLY

DATE: JAN. 2026

DRAWN BY: DA

CITY ENGINEER:

DocuSigned by:

Hae Won Ritchie

APPROVED BY:

HAE WON RITCHIE

R.C.E. C6953Z

W-06

DETAIL NO: