



**NOTES**

1. FIRE SERVICE LINE SIZE MINIMUM IS 1.5" AND MAY INCREASE DEPENDING UPON FIRE CALCULATIONS. CONTROL OR SHUT OFF VALVES ARE NOT PERMITTED BETWEEN THE CITY WATER METER AND THE BASE OF THE RISER FOR THE FIRE SPRINKLER SYSTEM.
2. SEPARATE PRIVATE SERVICE LINES ARE REQUIRED FOR DOMESTIC WATER AND FIRE SERVICE NEEDS AFTER THE CITY WATER METER. SERVICE LINES MUST BE INSTALLED PER U.P.C. REQUIREMENTS
3. THE CUSTOMER SHALL INSTALL SUITABLE CONTROL VALVES ON EACH PRIVATE SERVICE LINE ON THE RISER OR A MAXIMUM DISTANCE OF 50' FROM THE METER.
4. COMBINATION FIRE/DOMESTIC SERVICE SHALL SERVE NO MORE THAN ONE (1) RESIDENTIAL UNIT.
5. CONNECTIONS BETWEEN THE DOMESTIC SERVICE LINE AND THE FIRE SERVICE LINE ARE NOT PERMITTED.
6. METER INSTALLATION MAY REQUIRE CITY ISSUED, ELECTRONIC RADIO READ UNIT, AT CITY'S DIRECTION.
7. SIZE OF SPRINKLER SERVICE LINE SHALL BE BASED UPON SPRINKLER FLOW CALCULATIONS FOR EACH RESIDENCE
8. WATER METER SHALL BE LOCATED WITHIN THE PUBLIC RIGHT-OF-WAY AND, WHEN POSSIBLE, OUTSIDE OF THE SIDEWALK AND WITHIN LANDSCAPED AREAS, UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER.



*City of San Bruno*  
*Standard Detail*

**1 1/2" COMBINATION FIRE & DOMESTIC WATER SERVICE**

DATE: JAN. 2026

DRAWN BY: DA

CITY ENGINEER:

DocuSigned by:

*Hae Won Ritchie*

APPROVED BY:

D1409F278D36D40A  
HAE WON RITCHIE

R.C.E. C69532

W-05A

DETAIL NO: