



DOCUMENT 00 50 20

BID ADDENDUM NO. 1

PROJECT TITLE: CITY PARK FIELDS

PROJECT NO. 51025

DATE: Thursday – July 31, 2025


TO: All Prospective Bidders and Plan Holders of Record

BY THIS NOTICE, the City of San Bruno hereby amends the referenced project bid documents as follows:

Additions are shown in underline. Deletions are shown in ~~strikeout~~.

1. Citywide Field Lights RFB Pre-Bid Meeting
 - Agenda & Minutes – Attached
 - Emailed Questions – Included

This Bid Addendum No. shall become part of the Contract Documents and all provisions of the Contract shall apply thereto. This Bid Addendum has been provided to all plan holders of record. **For a bid to be considered as responsive for the purposes of an award of contract, this Bid Addendum shall be acknowledged in the appropriate section of the Bid Form, Document 00 41 70 (Addenda Acknowledgement).**

Signed by:

16E1C691E6614DA...

ISSUED BY: _____ Date: 8/1/2025

Travis M. Karlen, Director

Attachments: Meeting Agenda
Meeting Minutes

-END OF DOCUMENT-



Phase II –Citywide Baseball Field Lights Upgrades Project No. 51025 Pre-Bid Meeting Agenda

Date: July 31, 2025 | 1:00PM

Location: Zoom Meeting 846 6318 1220

CITY REPRESENTATIVES

- Dan Venezia, Parks Manager
- Audrey Afe-Tuufuli, Business Manager

2. Meeting Facilitator: Audrey Afe-Tuufuli

1. Welcome and Introductions

- o Participants:
 1. **Azul Works, Inc.**
 2. Leo, **Azul Works**
 3. Guillermo Acosta, **CF Contracting**
 4. John Parlog, **GBL Infrastructure Solutions Inc.**
 5. Eduardo Ramirez, **SFE-Inc**
 6. Shannon, **Silverfox Electric Inc.**
 7. Estimating, **SCC Electric**
 8. Kevin Keane, **WESCO|Anixter**
 9. Jane Kim, **Sfadia Inc**
 10. Andrew Cox
 11. Ryan Hayes
 12. Cody Lunsford

2. Project Overview – Dan Venezia, Parks Manager

- o Brief Recap of the Project (Citywide Baseball Field Lights Upgrades (No. 51025)
 1. City Fields Specifics
 2. Access to site is not required or needs an appoint to assess the sites.
Bidders are welcome to visit at their leisure.
- o Project goals and expected outcomes

3. Scheduling and Key Dates – Dan Venezia, Parks Manager

- o Present project timeline | Remaining Dates
 1. Deadline to Submit Q&A – 8/11/2025 4PM
 2. Deadline to Receive Bids – 8/20/2025 2PM
 3. Bid Opening – 8/20/2025
 4. Tentative Award of Contract – September 09,2025

4. Communication Protocols

- o All communication for this project should be addressed to:
 1. Travis M. Karlen – Director
csdcontracts@sanbruno.ca.gov

5. Next Steps

- o Addenda – posted to Barker Blue & City's Bid Post Pages



CITY WIDE FIELD LIGHTS UPGRADES PRE-BID MEETING QUESTIONS

Question No. 1: Is there an Engineer's Estimate for the project?

Answer: No.

Question No. 2: City have a certain or specific products for the project?

Answer: City is not requesting a specific brand, or product. Project needs to meet minimum light levels for fields.

Question No. 3: Can there be a substitute to fixtures?

Answer: No specific product is being asked of in the RFB. Bidder must provide products that are "code-compliant LED lighting to Illuminating Engineering Society (IES) standards" (RFB pg. 6)

Question No. 4: Does City have any specifications or drawings on the poles and fixtures?

Answer: There were no "As Built" drawings identified at the time of this RFB. Park Manager Venezia is knowledgeable and can answer to any questions related to lighting wiring and fixtures. These question do need to be submitted in writing and will be answered as part of a future addendum.

Question No. 5: What is the voltage on the lights?

**Answer: Lara Field & Diamond 1 & Diamond 2 – 480 voltage
Diamond 3 is 277 volts**

EMAILED QUESTIONS

Emailed Question No. 1:

It appears to be pretty straight forward and based on recreational Class IV levels (30/20 FC). Our KSL2 series 600W would be the way to go and meets DLC certification and includes a 10-year warranty which exceeds the requirements in the RFP.

Is Bidder providing the design and including new pre-wired and pre-aimed crossarms for quote?

Answer: Design by bidder is not required. City presumes install will comply with manufacturers installation Spec sheets for wiring and power connectivity.